



**FORM B 13.3**  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2024/00060804  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2024/00060804/R1

Date: 02/06/2025

Building Occupancy/Category: Educational (non-residential)

To,

**SHREE SWAMINARAYAN ACADEMY, SHRI SWAMINARAYAT H.V VIDHYALAYA**  
NEW RANDER ROAD, ADAJAN, SURAT ADAJAN SURAT Surat MC 395009  
Fire Region: Surat MC  
Mobile No: 9924644334 Email ID: Mukesh.dobaria09@gmail.com

This has reference to your Application No. **2025/00061357** dated 02/06/2025 for Fire Safety Certificate Renewal (FSCR) for the building/premise **SHREE SWAMINARAYAN ACADEMY, SHRI SWAMINARAYAT H.V VIDHYALAYA** (name of the Building/ Project), as per below mentioned details:

1. TP Number: 12
2. FP Number: 173
3. Survey Number:
4. Village Name: SURAT
5. Name of Block(s): SHREE SWAMINARAYAN ACADEMY SHRI SWAMINARAYAT H V VIDHYALAYA

The building/premise was inspected on **02/06/2025** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **02/06/2025**
2. Six monthly inspection was done on **02/06/2025**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **02/06/2027** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



**Digitally Verified**

Digitally verified by: Akshay Dilipbhai Patel  
Fire Safety Officer - General (FSO-G)  
2021/001402

Date: 02/06/2025  
Time: 07:13 PM



FSCA/O/CFOSMC/2024/00060804/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*